

EQUIPMENT INSPECTION AND TEST REPORT/CERTIFICATE

TEST EQUIPMENT DETAILS

Test Equipment used	Ethos 9100	Serial Number	01P-0079
Tested by	Coila Watt	Date	28/08/23
		11 Grampian Court Aviemore	

Asset ID	Description/Serial No	Location	Test Date	Next Test Date	Visual P/F	Fuse rating (A)	Earth Bond/Continuity (Ω)	Insulation resistance (MΩ)	Leakage (mA)	Polarity	Overall P/F	Comments
001	Vax Steamer	Cupboard	28/08/23	-	P	13a	-	19.99	0.10	-	P	
002	Russell Hobbs Iron	"	"	-	P	13a	0.14	19.99	0.10	-	P	
003	Numatic Vacuum	"	"	-	P	13a	-	19.99	0.10	-	P	
004	Dehumidifier	Double	"	-	P	13a	-	19.99	0.10	-	P	
005	Bedside Lamp Left	"	"	-	P	13a	-	19.99	0.10	-	P	
006	Bedside Lamp Right	"	"	-	P	3a	-	0.10	10.50	-	F	
007	4 Gang Extension Board	"	"	-	P	10a	0.03	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
008	Bedside Lamp	Twin Room	"	-	P	3a	-	19.99	0.10	-	P	
009	4 Gang Extension Board	"	"	-	P	13a	0.03	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
010	Dehumidifier	"	"	-	P	13a	-	19.99	0.10	-	P	
011	4 Gang Extension Board	"	"	-	P	10a	0.03	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
012	Standard Lamp	Living room	"	-	P	3a	-	19.99	0.10	-	P	
014	4 Gang Extension Board	"	"	-	P	10a	0.03	19.99	-	-	P	Good



Asset ID	Description/Serial No	Location	Test Date	Next Test Date	Visual P/F	Fuse rating (A)	Earth Bond/Continuity (Ω)	Insulation resistance (M Ω)	Leakage (mA)	Polarity	Overall P/F	Comments
014	4 Gang Extension Board	Living Room	28/08/23	-	-	-	0.03	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
015	4 Gang Extension Board	"	"	-	P	10a	0.03	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
016	Standard Lamp	"	"	-	P	3a	-	19.99	0.10	-	P	
017	4 Gang Extension Board	"	"	-	P	10a	0.02	19.99	-	-	P	Good
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
018	Beko Fridge	Kitchen	"	-	P	13a	0.06	19.99	0.10	-	P	
019	Freezer	"	"	-	P	13a	0.10	19.99	0.12	-	P	
020	George Kettle	"	"	-	P	13a	0.07	19.99	0.10	-	P	
021	Silvercrest Kettle	"	"	-	P	13a	0.07	19.99	0.10	-	P	
022	Samsung Microwave	"	"	-	P	10a	-	-	-	-	P	
023	Russell Hobbs Toaster	"	"	-	P	13a	0.10	19.99	0.10	-	P	
024	4 Gang Extension Board	Cupboard	"	-	P	13a	0.03	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
025	LG TV	Living Room	"	-	P	5a	-	19.99	0.10	-	P	
026	4 Gang Extension Board	"	"	-	P	13a	0.07	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.05	19.99	-	-	P	"
-	-	"	"	-	-	-	0.05	19.99	-	-	P	"
-	-	"	"	-	-	-	0.05	19.99	-	-	P	"
027	6 Gang Extension Board	"	"	-	P	13a	0.04	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.04	19.99	-	-	P	"
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
-	-	"	"	-	-	-	0.04	19.99	-	-	P	"



Asset ID	Description/Serial No	Location	Test Date	Next Test Date	Visual P/F	Fuse rating (A)	Earth Bond/Continuity (Ω)	Insulation resistance (MΩ)	Leakage (mA)	Polarity	Overall P/F	Comments
027	6 Gang Extension Board	Living Room	28/08/23	-	-	-	0.03	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"

Asset ID	Description/Serial No	Location	Test Date	Next Test Date	Visual P/F	Fuse rating (A)	Earth Bond/Continuity (Ω)	Insulation resistance (M Ω)	Leakage (mA)	Polarity	Overall P/F	Comments