

EQUIPMENT INSPECTION AND TEST REPORT/CERTIFICATE

TEST EQUIPMENT DETAILS

Test Equipment used	Ethos 9100	Serial Number	01P-0079
Tested by	Coila Watt	Date	28/08/23
		8 Grampian Court Aviemore	

Asset ID	Description/Serial No	Location	Test Date	Next Test Date	Visual P/F	Fuse rating (A)	Earth Bond/Continuity (Ω)	Insulation resistance (MΩ)	Leakage (mA)	Polarity	Overall P/F	Comments
001	Vax Steamer	Cupboard	28/08/23	-	P	13a	-	19.99	0.10	-	P	
002	Tesco Iron	"	"	-	P	13a	0.09	19.99	0.10	-	P	
003	Numatic Vacuum	"	"	-	P	13a	-	19.99	0.10	-	P	
004	6 Gang Extension Board	"	"	-	P	13a	0.03	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
005	4 Gang Extension Board	Twin Room	"	-	P	13a	0.03	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
006	Bedside Lamp	"	"	-	P	3a	-	0.10	10.50	-	F	
007	Dehumidifier	"	"	-	P	13a	-	19.99	0.10	-	P	
008	4 Gang Extension Board	"	"	-	p	10A	0.03	19.99	-	-	P	Good
-	-	"	"	-	-	-	0.03	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
-	-	"	"	-	-	-	0.02	19.99	-	-	P	"
009	Dehumidifier	Double	"	-	P	13a	-	19.99	0.10	-	P	
010	Bedside Lamp Left	"	"	-	P	3a	-	19.99	0.10	-	P	
011	Bedside Lamp Right	"	"	-	P	3a	-	19.99	0.10	-	P	



