

EQUIPMENT INSPECTION AND TEST REPORT/CERTIFICATE

TEST EQUIPMENT DETAILS

Test Equipment used	Ethos 9100	Serial Number	01P-0079
Tested by	Coila Watt	Date	28/08/23
		9 Grampian Court Aviemore	

Asset ID	Description/Serial No	Location	Test Date	Next Test Date	Visual P/F	Fuse rating (A)	Earth Bond/Continuity (Ω)	Insulation resistance (MΩ)	Leakage (mA)	Polarity	Overall P/F	Comments
001	Russell Hobbs Kettle	Kitchen	28/08/23	-	P	13a	0.13	19.99	0.10	-	P	
002	Samsung Microwave	"	"	-	P	10a	-	-	-	-	P	
003	Russell Hobbs Kettle	"	"	-	P	13a	0.37	19.99	0.10	-	P	
004	Fridge/Freezer	"	"	-	P	13a	0.17	19.99	0.10	-	P	
005	Innex Washing Machine	"	"	-	P	13a	0.04	19.99	3.24	-	P	
006	George Steamer	"	"	-	P	13A	0.07	19.99	0.10	-	p	
007	Russell Hobbs Iron	"	"	-	P	13a	0.05	19.99	0.10	-	P	
008	Vax Steam Cleaner	Hall Cupboard	"	-	P	13a	-	19.99	0.10	-	P	
009	Numatic Vacuum	"	"	-	P	13a	-	19.99	0.10	-	P	
010	Table Lamp Square	"	"	-	P	3a	-	19.99	0.10	-	P	
011	Table Lamp Round	"	"	-	P	3a	-	19.99	0.10	-	P	
012	Dehumidifier	"	"	-	P	13a	-	19.99	0.10	-	P	
013	Dehumidifier	"	"	-	P	13a	-	19.99	0.10	-	P	
014	Standard Lamp	Living Room	"	-	P	3a	-	19.99	0.10	-	P	
015	4 Gang Extension Board	"	"	-	P	13a	0.03	19.99	-	-	P	Good
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
016	LG TV	"	"	-	P	3a	-	19.99	0.10	-	P	
017	Standard Lamp	"	"	-	P	3a	-	19.99	0.10	-	P	
018	4 Gang Extension Board	"	"	-	P	13a	0.03	19.99	-	-	P	Good
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"



Asset ID	Description/Serial No	Location	Test Date	Next Test Date	Visual P/F	Fuse rating (A)	Earth Bond/Continuity (Ω)	Insulation resistance (M Ω)	Leakage (mA)	Polarity	Overall P/F	Comments
018	4 Gang Extension Board	Living Room	28/08/23	-	-	-	0.03	19.99	-	-	P	Good
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
019	Standard Lamp	"	"	-	P	3a	-	19.99	0.10	-	P	
020	4 Gang Extension Board	"	"	-	P	10a	0.03	19.99	-	-	P	Good
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"
021	6 Gang Extension Board	"	"	-	P	13a	0.03	19.99	-	-	P	Good
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
022	Bedside Lamp	Twin Room	"	-	P	3a	-	19.99	-	0.10	P	
023	3 Gang Extension Board	"	"	-	P	13a	0.04	19.99	-	-	P	Good
-	-	-	"	-	-	-	0.06	19.99	-	-	P	"
-	-	-	"	-	-	-	0.05	19.99	-	-	P	"
024	4 Gang Extension Board	"	"	-	P	10a	0.03	19.99	-	-	P	Good
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
025	4 Gang Extension Board	Double Room	"	-	P	10a	0.03	19.99	-	-	P	Good
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
-	-	-	"	-	-	-	0.02	19.99	-	-	P	"
026	Alarm Clock	"	"	-	P	3a	-	19.99	0.10	-	P	
027	Bedside Lamp Left	"	"	-	P	3a	-	19.99	0.10	-	P	
028	Bedside Lamp Right	"	"	-	P	3a	-	19.99	0.10	-	P	
029	4 Gang Extension Board	"	"	-	P	13a	0.03	19.99	-	-	P	Good
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"
-	-	-	"	-	-	-	0.03	19.99	-	-	P	"



